## Mandatory Language for a Maximum Contaminant Level Violation MCL, SINGLE SAMPLE / NITRATE

The Texas Commission on Environmental Quality (TCEQ) has notified **SILVER CREEK VILLAGE WSC** (PWS 0270021) public water system that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for nitrate. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for nitrate to be 10 milligrams per liter (mg/L) based on a single sample and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for nitrate indicates a compliance value in:

## 2Q2023 of 12 mg/L at LIVE OAK PLANT 1 - 300 MCKAY RD, BURNET

Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome. If your child is under the age of six months, the child **must** be given an alternative water supply for any consumption. Boiling the affected water is **not** an effective treatment for nitrate removal.

Most consumers do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you. At this time, the health effects to fetuses of pregnant women are unclear. If you are pregnant, you may also choose to use an alternative source of water for drinking and cooking purposes.

We are taking	the follo	wing	actions	to address this is	sue: WE	DRILLES	A	REPLACEM	ENT
				PROCESS OF					
A SWTI	0.			,		<	corre	ective actions>	

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact:

Instructions for preparing the required Public Notice:

Recopy the mandatory language above and insert the underlined information in the spaces indicated.

The TCEQ recommends that the public water system provide a copy of the Public Notice(s) to local and state officials, such as Mayors, City Council Members, County Commissioners, Judges, and/or State Representatives, that are located in or that represent the affected area(s) served by the system.

## Public Notice delivery timelines:

The initial public notice shall be issued as soon as possible, but in no case later than **24 hours** after the violation has been identified. Repeat public notice shall be issued every 90 days for as long as the violation persists. All notifications require the attached Certificate of Delivery due 10 days from the posting date of the above notice.

Refer to 30 TAC §290.122 for additional information on Public Notification.



## Texas Commission on Environmental Quality CERTIFICATION OF DELIVERY OF PUBLIC NOTICE TO CUSTOMERS Public Notice to be posted within 24 hours of violation notification

Public Water System (PWS) Name: SILVER CREEK VILLAGE WSC PWS ID: 0270021 Violating Constituent: AMCL NITRATE Time Period of Violation:

2Q2023 of 12 mg/L at LIVE OAK PLANT 1 - 300 MCKAY RD, BURNET

I, CAGLE, certify that the following information is true and accurate:  (print name)  The PWS named above has distributed the Public Notice (PN) for the violation listed above, by:
Mail or direct delivery, to bill-paying customers as required by 30 TAC §290.122 for community water systems, or
Continuous posting or direct delivery as required by 30 TAC §290.122 for <b>non-transient</b> , <b>non-community</b> water systems; and The information contained in this public notification is correct and complies with required public notification content in accordance with 30 TAC §290.122; and
In addition to the mandatory mail/direct delivery, the above system has made an adequate good-faith effort to reach non-bill-paying consumers by appropriate methods (check all below that apply):
Certified by: Name: (print) CLINT CAGLE Title: PRESIDENT Phone: 830-262-9164
Date of Delivery to Customers: Month 2 / Day 10 /Year 24
Signature: Chit Gh Date signed: $\frac{2/13/24}{}$
Email me copies of all of these completed forms to <a href="mailto:sally.paramo@tceq.texas.gov">sally.paramo@tceq.texas.gov</a> or mail the copies to:  Attn: Public Notice
Drinking Water Standards Section - Mail Code 155 Texas Commission on Environmental Quality (TCEQ); P. O. Box 13087; Austin, TX 78711- 3087