

SILVER CREEK VILLAGE WSC

METER TEST AUTHORIZATION AND TEST REPORT

NAME: _____

ADDRESS: _____

DATE OF REQUEST: _____ PHONE # (DAY): _____

ACCOUNT NUMBER _____ METER SERIAL NUMBER: _____

REASONS FOR REQUEST: _____

Member requesting a meter test may be present during the test, but if not, Member shall accept test results shown by the Corporation. The test shall be conducted in accordance with the American Water Works Association standards and methods on a certified test bench. Member agreed to pay \$50.00 for the test if the results indicate an AWWA acceptable performance, plus any outstanding water utility service. In the event that the Member is required to pay for the test and for outstanding water utility service as set forth herein, said charges shall be applied to the next billing sent to the member after the date of the test.

X _____

Signed by Member

TEST RESULTS

Low Flow (1/4 GPM) _____% AWWA Standard 97.0 103.0%

Intermediate (2 GPM) _____% AWWA Standard 98.5 101.5%

High Flow (10 GPM) _____% AWWA Standard 98.5 101.5%

_____ Meter tests accurately; no adjustments due

_____ Meter tests high; adjustment due on water charges by _____%

_____ Meter tests low; no adjustment due

Test conducted by _____

Approved _____